

Aghakhani, Ryan

From: Moosbrugger, Earl
Sent: Tuesday, June 07, 2016 10:19 AM
To: Hwang, Jin; Aghakhani, Ryan
Subject: RE: swimming pool initial fill

Our methodology is to only use the ETo.

Thank you!

From: Hwang, Jin
Sent: Tuesday, June 07, 2016 10:17 AM
To: Moosbrugger, Earl; Aghakhani, Ryan
Subject: swimming pool initial fill

Earl and Ryan,

For the Crossroads Hollywood project, the initial fill volume is 53,990 cf. This amount over the estimated life of the pool (30 years) results in 13,462 gal/yr, or 37 gpd.

Since this is a negligible amount, what do you think about only accounting for evaporation for swimming pool water demand? For the Crossroads Hollywood project, evaporation is 1,152 gpd, or 1.29 afy.